Major Source New Boiler with Light Liquid Fuel Subcategory

Capacity or	Oxygen	Initial Notice	Conduct an Initial	Tune-up	Complete	Required to Meet	Submit Initial	Emission Performance	Compliance
Use Type	Trim	of	Tune-up	Frequency	One-Time	Emission Limits ₁	Notification of	Test Frequency	Certification
	System?	Applicability			Energy		Compliance		Report ₂
					Assessment		Status		
≤ 5		within 15 days	Within 61 months	Every five					01/31/17
MMBTU/hr	_	of start-up	of start-up	(5) years	_	_	_	_	
< 10	Yes	within 15 days	Within 61 months	Every five					01/31/17
MMBTU/hr		of start-up	of start-up	(5) years	_	_	_	_	
< 10	No	within 15 days	Within 25 months	Every two					01/31/17
MMBTU/hr		of start-up	of start-up	(2) years	_	_	_	_	
≥ 10	Yes	within 15 days	Within 61 months	Every five		4.4 x 10 ⁻⁴ HCl, and 4.8 x		None if initial	01/31/17
MMBTU/hr		of start-up	of start-up	(5) years		10 ⁻⁷ Hg, 130 ppm CO,	60 days after	performance test is less	
					_	1.1 x 10 ⁻³ PM or TSM	compliance	than or equal to half the	
						within 180 days of	demonstration	limit, otherwise every	
						startup		three (3) years	
≥ 10	No	within 15 days	Within 13 months	Annually		4.4 x 10 ⁻⁴ HCl, and 4.8 x		None if initial	01/31/17
MMBTU/hr		of start-up	of start-up			10 ⁻⁷ Hg, 130 ppm CO,	60 days after	performance test is less	
					_	1.1 x 10 ⁻³ PM or TSM	compliance	than or equal to half the	
						within 180 days of	demonstration	limit, otherwise every	
						startup		three (3) years	
Limited Use		within 15 days	Within 61 months	Every five					01/31/17
	_	of start-up	of start-up	(5) years	_	_	_	_	

A *Limited Use* boiler means any boiler that burns any amount of solid or liquid fuels and has a federally enforceable average annual capacity factor of no more than 10%.

- 1. Boiler emission limits can be found in 40 CFR 63, Subpart DDDDD Table 1 for new and reconstructed boilers and vary depending on the type of boiler and boiler capacity.
- 2. First Compliance Certification Report is due **January 31, 2017** and subsequent reports are due semi-annually, annually, biennially, or every five (5) years depending on the boiler type and capacity.